

超微量工業安全實驗室

Ultra Trace & Industrial Safety Hygiene

測試報告

報告編號: US/2020/30254A-01 日期: 2020年 03月 31日 頁數: 1 of 3

安洲股份有限公司

新北市新北產業園區五權路 2-1 號 8 樓

以下測試之樣品係由申請廠商所提供及確認:

 樣品名稱:
 Steril-Aire DE62"

 申請廠商:
 安洲股份有限公司

 採樣地點:
 欣興電子股份有限公司

採樣點位名稱: 於興電子空調箱 AHU-503 冰水盤管

採樣單位: 台灣檢驗科技股份有限公司-超微量工業安全實驗室

採樣日期: 2020 年 03 月 12 日 收樣日期: 2020 年 03 月 12 日

測試日期: 2020年03月12日~2020年03月20日

測試項目: 表面接觸菌測試

测試方法: 本測試用培養皿以均等壓力接觸待測表面數秒,並無任何直線或環狀移動,採樣完畢攜回

培養皿放置恆溫培養箱(30~35℃)中 3~5 天後計數。

測試結果: - 請見下頁 -

SGS Taiwan Ltd.
Sharyh ChenSGS

Shin-Jyh Ch'en

Signed for and on behalf

Manager

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

台灣檢驗科技股份有限公司

No.38, Wu Chyuan 7th Rd., New Taipei Industrial Park, Wu Ku District, New Taipei City, 24890, Taiwan/ 新北市五股區新北產業園區五權七路38號 t+ (886-2) 2299-3939 f+ (886-2) 2298 -1338 www.tw.sgs.com



超微量工業安全實驗室

Ultra Trace & Industrial Safety Hygiene

測試報告

報告編號: US/2020/30254A-01

安洲股份有限公司

新北市新北產業園區五權路 2-1 號 8 樓

測試結果:

表面接觸微生物測試

| 採樣點名稱 | 測試結果 | 定量極限/ 偵測極限 | 單位 |
|-------|------|---------------|-----------|
| 1 | 10 | 1 | CFU/plate |
| 2 | 4 | 1 | CFU/plate |
| 3 | 15 | 1 | CFU/plate |
| 4 | 57 | 1 | CFU/plate |
| 5 | 15 | 1 | CFU/plate |
| 6 | 5 | 1 | CFU/plate |

備註: 1. 測試報告僅就委託者之委託事項提供測試結果,不對產品合法性做判斷。

- 2. 本報告不得分離,分離使用無效。
- 3. 若該測試項目屬於定量分析則以「定量極限」表示;若該測試項目屬於定性分析則以 「偵測極限」表示。
- 4. 低於定量極限/偵測極限之測定值以"N.D."或"陰性"表示。微生物測試低於定量極限以"<定量極限值"表示。
- 5. SGS 台灣實驗室為台灣 TAF 所認可之符合 ISO 17025 實驗室,並非 US FDA GMP 所認可之實驗室。SGS 台灣實驗室所提出之測試數據資料及報告,與 GMP 規範之要求不一定符合;若任一方使用 SGS 台灣實驗室所提出之測試數據資料及報告,進行 US FDA/EU 之新藥等申請,SGS 將不承擔所產生之任何責任。
- 6. 此份報告取代 US/2020/30254 報告(修正樣品名稱,2020/03/31)。

- END -

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd. 台灣檢驗科技股份有限公司 2020年03月31日 頁數: 2 of 3



超微量工業安全實驗室

Ultra Trace & Industrial Safety Hygiene

測試報告

報告編號: US/2020/30254A-01

日期: 2020年03月31日 頁數: 3 of 3

安洲股份有限公司

新北市新北產業園區五權路 2-1 號 8 樓

採樣位置圖



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

SGS Taiwan Ltd. 台灣檢驗科技股份有限公司 No.38, Wu Chyuan 7th Rd., New Taipei Industrial Park, Wu Ku District, New Taipei City, 24890, Taiwan/新北市五股區新北產業園區五權七路38號